

Total Hardness
Range: 50 - 1000 ppm

AE541

Directions for Use:-

1. Take 10 ml of water sample to be tested in the test jar.
2. Add one spoonful (provided herewith) of TH 1L.
3. Mix contents well to dissolve.
4. Add 10-12 drops* of TH 2 and mix contents well.
5. If colour turns blue, it indicates there is 'No Hardness' in the water.
6. If colour turns red, it indicates there is 'Hardness'.
7. Now drop wise* add TH 6, counting the number of drops while mixing, until the colour changes from red to blue.

Calculations:

Total Hardness as $\text{CaCO}_3 = 50 \times (\text{Number of drops of TH 6})$

For controlled addition of drops, follow instructions on the dispenser.

WATER ANALYZING WATER
Anytime... Anywhere...

